



Addendum Number 2

Bid: Blackstrap Road Shoulder Box Cut
Town of Falmouth – Public Works Department
Falmouth, ME

Date: July 25, 2019

From: Justin Early, Town Engineer

Questions, Clarifications, and Additional Information:

Questions:

1. *“Will there be any loam and seed required with this project?”*

Answer: No. Loam and seed will be conducted by others when the road is paved under a separate contract.

2. *“Will the shoulder box-cut include digging through the driveways or will they be skipped? And if so, will the contractor be responsible for saw cutting?”*

Answer: The work will include box cutting through the driveways. Falmouth Public Works has been in the process of replacing the culverts at the driveways. Many of the driveways have saw cuts that can be utilized for pavement removal for the box cut. However, if a driveway does need to be cut, then yes, it should be included with your lump sum price.

Please acknowledge receipt of this addendum by either emailing (jeary@falmouthme.org) a confirmation receipt, or writing in an acknowledgement on the bid form to be submitted.